



City of Encinitas
Fire Department

505 S. Vulcan Ave.
Encinitas, CA 92024-3633
(760) 633-2800

June 3, 2010

To Whom It May Concern:

The City of Encinitas is requesting proposals for the purchase of a Compressed Air Foam System (CAFS) Unit. Enclosed you will find the minimum specifications and provider requirements for the CAFS unit that we intend to purchase.

Please use the section under "Proposal" to identify the unit (model) for which you are submitting proposals and its cost (including tax and delivery), and return it along with any other information you wish to include. **Proposals will be accepted until Monday, June 14, 2010 at 2:00 p.m. (Pacific Time).**

Please mail or deliver your proposal to the following address:

City of Encinitas
Fire Department
Attn: Scott Henry
505 S. Vulcan Avenue
Encinitas, CA 92024

Proposals may also be transmitted by fax to (760) 633-2818. All proposals, mailed, faxed or delivered, must be received on or before **June 14, 2010 at 2:00 p.m. (Pacific Time)** to be considered. All providers will be notified of the selected proposal.

Thank you for your interest in doing business with the City of Encinitas Fire Department. Please feel free to contact me at (760) 633-2804 or by e-mail at jhenry@ci.encinitas.ca.us if additional information or clarification is needed.

Respectfully,

J. Scott Henry
Deputy Fire Chief
City of Encinitas Fire Department

REQUEST FOR PROPOSALS

ITEM: Compressed Air Foam System Unit

Required Minimum Specifications:

- “Slide-In” Type
- Self-Contained
- Forklift Lifting Points
- 4 Eyelets on the Upper Corners (for vertical lifting with hoist)
- Minimum 36 Horse Power Engine
- Diesel Powered
- Minimum 15 Gallon Fuel Tank
- Minimum 100 GPM Pump
- Minimum 50 CFM Compressor
- Minimum 200 Gallon Water Tank
- Minimum 10 Gallon “A” Foam Tank
- Minimum of 2 - 1½ inch Discharge Outlets
- 150 feet of Hose Reel Line
- Dedicated Battery-Charging System
- Minimum 1-Year Warranty on Entire Unit
- Built in accordance with the National Fire Protection Association Apparatus Standard.
- California Emissions Compliant (CARB)
- Delivery to 801 Orpheus Avenue, Encinitas, California, 92024.

Provider Requirements:

- Provider must allow an inspection at the factory before final purchase and delivery of the unit.

Proposal:

Please provide the following information:

Proposed Unit Model: _____

Proposed Unit Net Cost: _____

Tax _____

Delivery: _____

Please attach additional information, such as photos and complete specifications, as well as sales contact information including name and phone number. Thank you very much.